

Authorised New Zealand Distributor Ph (09) 483 4000 www.firestopcentre.co.nz




## **3M™** Fire Protection

## **Design Specification Sheet: 3M Tuck-In Wrap Strip Concrete Wall**

| Through Penetration | Construction Type  | FRR             | Compliance Report   |  |
|---------------------|--|-----------------|---|--|
| PVC or PVC-U Pipe   | Concrete, AAC, masonry or solid block wall min 100mm thick | Up to -/120/120 | AS 1530.4:2014 & AS 4072.1-2005<br>BRANZ FC10453 Page 11<br>System/FPA Register ID# FC087 |  |

## 3M<sup>™</sup> Fire Barrier Tuck-In Wrap Strip Fire Stopping System PVC or PVC-U Pipes in 100mm Concrete, AAC or Masonry Walls



## Installation

- 1. PVC-U Pipe, pipe sizes as per Table 1
- 2. 3M™ Tuck-In Wrap Strip fitted closely around the pipe and pushed into the wall leaving approx 20mm protruding from the wall each side.
- 3. Single layer systems require a 10mm deep bead of 3M IC15WB+ Sealant within the annular space between the Wrap Strip and the wall (minimum annular space 10mm).
- 4. Double layer systems with the minimum annular gap of 10mm do not require 3M IC15WB+ Sealant within the gap but there must be a fillet of at least 5mm applied at the wall/Wrap junction (see illustration above).
- Finally apply a bead of 3M IC15WB+ Sealant around the Wrap Strip/pipe junction.
  NOTE: The more highly intumescent 3M CP 25WB+ sealant may be substituted for 3M IC 15WB+ (Warringtonfire RIR 23263 pg 4)

Table 1 - PVC-U Pipe and Aperture Size for 3M™ Tuck-In Wrap Strip in Concrete Walls

| Pipe Outside<br>Diameter | Minimum Annular<br>Gap | Maximum Annular<br>Gap | Pipe wall<br>Thickness | No. of<br>Wraps | FRR       |
|--------------------------|------------------------|------------------------|------------------------|-----------------|-----------|
| Up to 50mm               | 10mm                   | 20mm                   | Up to 3.7mm            | 1               | -/120/120 |
| Up to 110mm              | 10mm                   | 20mm                   | Up to 5.3mm            | 2               | -/120/120 |
| Up to 110mm              | 10mm                   | 20mm                   | Up to 3.2mm            | 1               | -/120/90  |
| Up to 110mm              | 10mm                   | 20mm                   | Up to 5.3mm            | 1               | -/60/60   |

NOTE: Where the FRR of the wall is less than the system FRR in Table 1 above then the lower FRR must be used.

Phone 136 136 (Option 2)
Email 3mindustrialaucs@mmm.com
Web www.3m.com.au

3M New Zealand Ltd Industrial Adhesives and Tapes Division 94 Apollo Drive, Rosedale Auckland 0632

Phone 0800 474 787 Email 3mnzitb@mmm.com Web www.3m.co.nz User is responsible for determining whether the 3M product is fit for a particular purpose and suitable for user's application. Limitation of Liability. Except where prohibited by law, 3M will not be liable for any loss or damage arising from this 3M product, whether direct, indirect, special, incidental or consequential, regardless of the legal theory asserted, including warranty, contract, negligence or strict liability. 3M and Interam are a trademark of 3M Company.