




Step-by-step installation instructions:


1. Ensure the aperture is free from dust and debris.
2. Exposed side: Wrap 1 x Pair Coil (PE or FR insulation) + 1 x 25mm uPVC pipe + 1 x TPS cable with AGNI-Wrap 50 and secure with one AGNI-Strap.
3. If there are two or three A/C bundles, wrap each of them the same way with AGNI-Wrap 50 & secure with AGNI-Strap to form separate A/C bundles.
4. Another revolution of AGNI-Wrap 50 is used to wrap together two/three separate A/C bundles and secure with AGNI-Strap.
5. Position AGNI-Wrap 50 so that 25mm of AGNI-Wrap 50 is on the exposed side and 25mm in the aperture.
6. Use AGNI-Seal to fill the gap between AGNI-Wrap 50 and the plasterboard.
7. Install AGNI-Clips from underneath to secure the installation.
8. Unexposed side: Services don't penetrate plywood lining.

System ID# FC824

①



②



Technical Information

Substrate	• Fire-rated plasterboard ceiling (min. one layer of 13mm plasterboard or greater)
Service range	1-3 x Pair PE/FR + 1-3 x 25mm uPVC pipe + 1-3 x TPS cables
Annular gap	3.5mm - 20mm
AGNI-Products	AGNI-Seal, AGNI-Wrap 50, AGNI-Clips, AGNI-Strap
Protection installation	Asymmetrical - installed on the fire side only

Compliance Information

Standards	AS1530.4-2014, AS4072.1-2005
FRR/FRL	-/45/45 in the ceiling with FRR 45/45/45 -/60/60 in the ceiling with FRR 60/60/60
Reference	RIRF24079 (AE-087)



Agnitek[®]
FIRE RATED TECHNOLOGY

8 Clare St Bayswater
VIC 3153, AUSTRALIA
www.agnitek.com.au

Disclaimer

Agnitek reserves the right to modify product specifications without prior notice due to its ongoing research, development & certification programme. The information in this document is provided in good faith and is intended for guidance purposes only. Any accompanying drawings are solely for illustrative purposes. Since Agnitek cannot oversee installation methods or ensure site conditions, no warranties, expressed or implied, are intended regarding the products' actual performance. We do not accept liability for any loss, damage, or injury from using this information. Please take a look at the test reports displayed on a relevant AGNI-System webpage for all compliance specifics.


Date 16.08.2024




FIRESTOP CENTRE

Authorised New Zealand Distributor
Ph (09) 483 4000 www.firestopcentre.co.nz

AGNI-Wrap in 13mm Plasterboard Ceiling Pair Coils (PE or FR) (up to 3) Up to FRR -/60/60



System ID# FC824



Technical Information

Substrate	• Fire-rated plasterboard ceiling (min. one layer of 13mm plasterboard or greater)
Service range	1-3 x Pair PE/FR + 1-3 x 25mm uPVC pipe + 1-3 x TPS cables
Annular gap	3.5mm - 20mm
AGNI-Products	AGNI-Seal, AGNI-Wrap 50, AGNI-Clips, AGNI-Strap
Protection installation	Asymmetrical - installed on the fire side only

Compliance Information

Standards	AS1530.4-2014, AS4072.1-2005
FRR/FRL	-/45/45 in the ceiling with FRR 45/45/45 -/60/60 in the ceiling with FRR 60/60/60
Reference	PF24079

Disclaimer

Agnitek reserves the right to modify product specifications without prior notice due to its ongoing research, development & certification programme. The information in this document is provided in good faith and is intended for guidance purposes only. Any accompanying drawings are solely for illustrative purposes. Since Agnitek cannot oversee installation methods or ensure site conditions, no warranties, expressed or implied, are intended regarding the products' actual performance. We do not accept liability for any loss, damage, or injury from using this information. Please take a look at the test reports displayed on a relevant AGNI-System webpage for all compliance specifics.




Agnitek[®]
FIRE RATED TECHNOLOGY

8 Clare St Bayswater
VIC 3153, AUSTRALIA
www.agnitek.com.au

Date | 16.08.2024

AGNI-Wrap in 13mm Plasterboard Ceiling Pair Coils (PE or FR) (up to 3) Up to FRR -/60/60

System ID# FC824



Technical Information

Substrate	<ul style="list-style-type: none"> Fire-rated plasterboard ceiling (min. one layer of 13mm plasterboard or greater)
Service range	1-3 x Pair PE/FR + 1-3 x 25mm uPVC pipe + 1-3 x TPS cables
Annular gap	3.5mm - 20mm
AGNI-Products	AGNI-Seal, AGNI-Wrap 50, AGNI-Clips, AGNI-Strap
Protection installation	Asymmetrical - installed on the fire side only

Compliance Information

Standards	AS1530.4-2014, AS4072.1-2005
FRR/FRL	-/45/45 in the ceiling with FRR 45/45/45 -/60/60 in the ceiling with FRR 60/60/60
Reference	PF24079



Agnitek[®]
FIRE RATED TECHNOLOGY

8 Clare St Bayswater
VIC 3153, AUSTRALIA
www.agnitek.com.au

Disclaimer

Agnitek reserves the right to modify product specifications without prior notice due to its ongoing research, development & certification programme. The information in this document is provided in good faith and is intended for guidance purposes only. Any accompanying drawings are solely for illustrative purposes. Since Agnitek cannot oversee installation methods or ensure site conditions, no warranties, expressed or implied, are intended regarding the products' actual performance. We do not accept liability for any loss, damage, or injury from using this information. Please take a look at the test reports displayed on a relevant AGNI-System webpage for all compliance specifics.

Date	16.08.2024
------	------------