

## Allproof Low Profile Fire Collar Plastic Pipe in Concrete Floor (from 70mm) See pg2 for details of PVC, PVC with socket, HDPE, Acoustic, Aquatherm, PEX, PB pipes

System/FPA Register ID# FC732

<b>Products</b>	Allproof Low-Profile Fire Collar
<b>Application</b>	Fire stopping of plastic pipes in rigid floors
<b>Construction</b>	Minimum floor thickness of 70mm and comprise aerated concrete or concrete

### Fire Classification:

See page 2 for details of slab, pipe and hole sizes for the following:

PVC up to 225mm diam	Up to FRR -/240/180
PVC with socket up to 100mm diam	Up to FRR -/240/180
HDPE up to 150mm diam	Up to FRR -/120/120
PP-R (Aquatherm) up to 110mm diam	Up to FRR -/120/120
Raupiano PP-MD up to 110mm diam	Up to FRR -/120/120
D Blue PP-MD up to 110mm	Up to FRR -/240/240
PEX, PB or PEX/Al/PEX up to 28mm	Up to FRR -/120/120

# ALLPROOF


INDUSTRIES

Allproof Industries Ltd  
 17 Bay Park Place  
 Beach Haven, AK 0626

Sheet size:	Drawn date & no:
<b>A4</b>	28/7/21
Scale:	Drawn by:
<b>NTS</b>	G.P

### INSTALLATION INSTRUCTIONS:

1. Ensure substrate around pipe is flat and free from obstructions.
2. Open pipe collar and position around pipe.
3. Slide tab through slot in pipe collar and fold back 180° to secure.
4. Secure pipe collar using M6x25 masonry anchors or M6x4.5 DBZ wedge anchors into the concrete slab. Do not use fixings which rely on plastic or nylon components for grip.
5. Install only from underside on floor penetrations.
6. Seal the annular space at the top of the slab with min 5mm of Allproof MAS310 fire sealant.



As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Firestop Centre has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied, is intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

For all technical details on the products specified please refer to the technical data sheets that can be found on [www.firestopcentre.co.nz](http://www.firestopcentre.co.nz)

Signed and approved:

## CONCRETE SLAB TEST RESULTS:

NOMINAL PIPE SIZE (MM)	SLAB DEPTH (MM)	NOMINAL PIPE WALL THICKNESS (MM)	PRODUCT CODE	PENETRATION HOLE SIZE (MM)	FLOOR FRL	REPORT NUMBER
<b>PVC PLASTIC PIPE</b>						
40	70	2.0	ALLFC40	47	-/90/60	6017
50	70	2.2	ALLFC50	57	-/90/60	4831
65	70	2.7	ALLFC65	72	-/90/60	4831
80	70	2.9	ALLFC80	87	-/90/60	4831
100	70	3.2	ALLFC100	112	-/90/60	6017
20	120	1.8	ALLFC25	28	-/120/120	5125
40	150	2.0	ALLFC40	47	-/120/120	3788
50	150	2.2	ALLFC50	57	-/120/120	3788
65	150	2.7	ALLFC65	72	-/120/120	4100
80	150	2.9	ALLFC80	87	-/120/120	3808
100	150	3.2	ALLFC100	112	-/120/120	3788
150	150	4.5	ALLFC150	162	-/120/120	4100
225	150	6.0	ALLFC250	262	-/180/180	145430
<b>PVC PLASTIC PIPE - WITH SOCKET</b>						
40	120	Socket	ALLFC40	47	-/240/180	5573
50	150	Socket	ALLFC50	57	-/120/120	4465
65	150	Socket	ALLFC65	72	-/120/120	4465
80	150	Socket	ALLFC80	87	-/120/120	4465
100	150	Socket	ALLFC100	112	-/120/120	3974
<b>PVC PLASTIC STORMWATER PIPE</b>						
225	150	6.0	ALLFC250	262	-/240/180	143281-004
<b>HDPE PLASTIC PIPE</b>						
50	150	3.0	ALLFC50	52	-/120/120	3974
56	150	3.0	ALLFC50	58	-/120/120	4834
63	150	3.0	ALLFC65	65	-/120/120	4834
75	150	3.0	ALLFC80	77	-/120/120	3974
110	150	4.3	ALLFC100	112	-/120/120	3974
150	150	6.2	ALLFC150	162	-/120/120	4100
<b>PP-R PLASTIC PIPE (SDR 7.4)</b>						
20	120	2.2	ALLFC25	28	-/120/120	5125
40	150	5.5	ALLFC40	42	-/120/120	4058
75	150	10.3	ALLFC80	77	-/120/120	4058
110	150	15.1	ALLFC100	112	-/90/90	4058
<b>RAUPIANO PP-MD</b>						
40	120	1.8	ALLFC40	42	-/120/120	5169
50	120	1.8	ALLFC50	52	-/120/120	5169
75	120	1.9	ALLFC80	77	-/120/120	5169
110	120	2.7	ALLFC100	112	-/120/120	5169

Continued on next page.

## CONCRETE SLAB TEST RESULTS (CONTINUED):

NOMINAL PIPE SIZE (MM)	SLAB DEPTH (MM)	NOMINAL PIPE WALL THICKNESS (MM)	PRODUCT CODE	PENETRATION HOLE SIZE (MM)	FLOOR FRL	REPORT NUMBER
D BLUE PP-MD						
40	120	1.8	ALLFC40	42	-/120/120	4467
50	120	1.8	ALLFC50	52	-/240/240	5573
75	120	2.3	ALLFC80	77	-/120/120	4467
110	120	3.4	ALLFC100	112	-/240/240	5573
OTHER PLASTIC PIPE						
16 PEX	120	2.35	ALLFC25	28	-/120/120	5125
20 PEX	120	2.95	ALLFC25	28	-/120/120	12424-001
25 PEX	120	3.75	ALLFC25	28	-/120/120	5125
16 PB	120	1.7	ALLFC25	28	-/120/120	5125
20 PB	120	2.1	ALLFC25	28	-/120/120	12424-001
28 PB	120	2.8	ALLFC25	32	-/120/120	5125
25 PEX/AL/PEX	120	2.8	ALLFC25	28	-/120/120	5125

Fixing: Collars tested using M6x25 masonry anchors or M6x45mm Wedge Anchors.