

Protecta FR Board Concrete Wall Blank Patress Fit

System/FPA Register ID# FC255

Products	Protecta FR Board Protecta FR Acrylic
Application	Fire stopping blanks in rigid walls
Construction	Minimum wall thickness of 150 mm and comprise concrete, aerated concrete or masonry, with a density of $\geq 650 \text{ kg/m}^3$

Fire & Sound classification


Blank seal up to 600 x 600mm FRR -/240/180

Wall thickness down to 75 mm accepted with FRR reduced to FRR of the wall.

Sound reduction (seal only) STC 55

Installation Instructions

1. Before installing Protecta® FR Board ensure that the surface of all service penetrations and surrounding construction is free from all loose contaminants, dust and grease.
2. Cut the board to suit the aperture dimensions allowing for 50mm overlap on all sides. All exposed and cut edges of the board must be sealed with Protecta® FR Acrylic.
3. All gaps or imperfections in the installed seal must be filled with Protecta® FR Acrylic on both sides.
4. Protecta® FR Board can be over-painted with most emulsion or alkyd (gloss) paints.



Protecta®

Polyseam Ltd, 15 St Andrews Road,
 Huddersfield, West Yorkshire, HD1 6SB

Tel: +44 (0) 148 4421036

Email: post.uk@polyseam.com

As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Polyseam has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied, is intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

For all technical details on the products specified please refer to the technical data sheets that can be found on www.firestopcentre.co.nz

Signed and approved:

Sheet size: **A4** Drawn date & no: 20/4/20

Scale: **NTS** Drawn by: G.P