


Protecta FR Collar - Plasterboard Wall Plastic Pipes up to 40mm Bundled

Installation Instructions

1. For sealing pipe bundles, a Protecta FR Collar is installed on both sides of the wall.
2. Before fitting the collar ensure that any gaps between the pipes and the separating element are sealed. Gaps between the pipes and the construction below 8mm must have a bead of Protecta FR Acrylic to cover the opening, and for gaps 8mm or above, the seal must be plugged with FR Acrylic to the depth of the plasterboard.
3. Place a collar around the pipes and ensure that the fixing lugs are positioned tightly to the surface of the wall so that the anchors/fixings can be inserted fully.
4. Where the surface is uneven, apply a sealing bead of Protecta® FR Acrylic between the wall and the collar.
5. Attach the collar with steel screws, anchors or fixings that are suitable for the number of boards that form the wall.
6. On sites where the penetration size is greater than the bundle diameter and/or the bundle is on an angle, an oversized collar can be used. Protecta® FR Collars are tested 'oversize', i.e. the internal diameter of the collar can be larger than the pipes.



System/FPA Register ID# FC598

Products	Protecta FR Collar Protecta FR Acrylic
Application	Fire stopping of plastic pipe bundles in flexible walls
Construction	Minimum wall thickness of 100 mm and comprise steel studs or timber studs lined on both faces with minimum 2 layers of 12.5 mm thick boards

Fire & Sound classification

Pipes $\leq \varnothing 40\text{mm}$, in a bundle $\leq \varnothing 110\text{mm}$, with collars $\leq \varnothing 110\text{mm}$ at $\geq 50\text{mm}$ height
FRR -/90/90

Pipes $\leq \varnothing 40\text{mm}$, in a bundle $\leq \varnothing 160\text{mm}$, with collars $\leq \varnothing 160\text{mm}$ at $\geq 60\text{mm}$ height
FRR -/90/90

Plastic pipes may be PVC-U, PVC-C, PE, HDPE, PEX, PP, PP-H, PP-MV, PP-R or similar.
A bundle can be any mix of the above.

ZERO smoke leakage up to 200Pa with 10mm FR Acrylic

Sound reduction (seal only) STC 58

As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Polyseam has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied, is intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

For all technical details on the products specified please refer to the technical data sheets that can be found on www.firestopcentre.co.nz

Signed and approved:

Sheet size: **A4**
Drawn date & no: 28/7/20

Scale: **NTS**
Drawn by: **K.B**