



# FIRESTOP CENTRE

Authorised New Zealand Distributor  
Ph (09) 483 4000 www.firestopcentre.co.nz

## RLA FirePro FR Sealant Pbd Wall Linear Gaps

### Vertical 20mm, Horizontal 40mm (with cable)



Test Reports PF22076, pg 26  
and PF22077, pgs 21,22  
AS1530.4-2014 AS4072.1-2005



System ID# FC347

<b>Products</b>	RLA FirePro FR Sealant
<b>Application</b>	Fire stopping of linear gaps in plasterboard walls (with cable)
<b>Construction</b>	Plasterboard wall 2 x 13mm min 116mm thick

<b>Fire Classification</b>	
<b>Up to 20mm vertical gap</b> with 26mm deep RLA FirePro FR sealant flush with plasterboard face	FRR -/120/120
<b>Up to 40mm horizontal gap</b> against head track with 26mm deep RLA FirePro FR sealant each side flush with plasterboard face	FRR -/120/120
<b>Up to 40mm horizontal gap</b> against head track with 26mm deep RLA FirePro FR sealant each side flush with plasterboard face and cable bundle max 20mm with cone of sealant	FRR -/120/120

#### INSTALLATION INSTRUCTIONS

1. Ensure surfaces are free of grease or other contaminants.
2. Apply RLA Firepro FR sealant to the depth of the plasterboard (nominal 26mm) on both sides flush with the plasterboard face.
3. A cable bundle max 20mm diam may penetrate the head track and be sealed with a cone of RLA FirePro FR sealant 50mm x 70mm as shown in diagram.



As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Firestop Centre has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied are intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

For all technical details on the products specified please refer to the technical data sheets that can be found on [www.firestopcentre.co.nz](http://www.firestopcentre.co.nz)

Signed and approved:



RLA Polymers Pty Ltd  
215 Colchester Rd, Kilsyth  
VIC 3137, AUSTRALIA

Sheet size: <b>A4</b>	Drawn date & no: 20/8/23
--------------------------	-----------------------------