

Regulatory Information Report

PF24102

**Fire resistance test for penetrations through a
vertical separating element**

Client: Agnitek Pty Ltd

Test method: AS1530.4-2014

Report Date: 15/11/2024

Test number: PF24102



Table of Contents

- 1.1 Document revision schedule 4
- 1.2 Signatories 4
- 2. Report Summary..... 5
- 3. General Information 6
 - 3.1 Testing Scope 6
 - 3.2 Contact Details..... 6
 - 3.3 Specimen Preparation, Conditioning and Timeline 7
 - 3.4 Use of the Report 7
- 4. Specimen Description..... 8
 - 4.1 Supporting Construction..... 8
 - 4.2 Specimens 8
- 5. Test Results..... 10
 - 6.1 Observations during the test 10
 - 6.2 Specimen 1 11
 - 6.3 Specimen 2 12
 - 6.4 Specimen 3 13
 - 6.5 Specimen 4 14
 - 6.6 Specimen 5 15
 - 6.7 Specimen 6 16
 - 6.8 Specimen 7 17
 - 6.9 Specimen 8 18
 - 6.10 Specimen 9 19
 - 6.11 Specimen 10 20



6.12 Specimen 11 21

6. Photos 22

7.1 Photos before the test 22

1.1 Document revision schedule

Revision #	Date	Description
1	15/11/2024	Issued to Client

1.2 Signatories

Report	Name	Signature	Date
Prepared by:	Alexey Kokorin		15/11/2024
Authorised by:	Andrew Bain (Authorized signatory)		15/11/2024



All tests reported herein have been performed in accordance with the laboratory's scope of accreditation

2. Report Summary

Service penetrations were tested through one layer of 13mm FR Plasterboard on each side of a 64mm (nominal) steel frame. Services were capped on the fire side.

Sp #	Service	Penetration side	Actual Integrity (min)	Actual Insulation (min)	FRL
1	2 x PE Pair Coils + 2 x TPS Cables	Both	66NF	66NF	-/60/60
2	2 x PE Pair Coils + 2 x TPS Cables	Fire side only	66NF	66NF	-/60/60
3	2 x PE Pair Coils + 2 x TPS Cables	Non-fire side only	66NF	66NF	-/60/60
4	PE Pair Coil + TPS Cable	Both	66NF	66NF	-/60/60
5	PE Pair Coil + TPS Cable	Fire side	66NF	65	-/60/60
6	PE Pair Coil + TPS Cable	Non-fire side only	66NF	66NF	-/60/60
7	25mm Aluminium Cable	Both	66NF	66NF	-/60/60
8	30mm Aluminium Cable	Both	66NF	66	-/60/60
9	52mm Aluminium Cable	Both	66NF	39	-/60/30
10	16mm PEX/AL/PEX Pipe	Both	66NF	65	-/60/60
11	12mm Threaded Rod	Both	66NF	66NF	-/60/60

NF – No failure during the test

3. General Information

3.1 Testing Scope

Applicable Standards:

AS 1530.4-2014 Section 10: Service penetrations and control joints

AS 4072.1-2005 (r. 2016) Components for the protection of openings in fire-resistant separating elements. Part 1: Service penetrations and control joints

Departures from Testing Method:

No departures from the testing method

Test conditions:

Conditions complied with the Standard

3.2 Contact Details

Accredited Testing Laboratory

Fire TS Lab - Passive Fire Inspection and Test Services Ltd

Accreditation Number - 1335

1/113 Pavilion Drive, Mangere, Auckland, 2022

New Zealand

Contact e-mail: tests@firelab.co.nz

Client/Applicant:

Agnitek Pty Ltd

8 Clare St, Bayswater, VIC, 3153

Australia

Contact e-mail: info@agnitek.com.au

Manufacturer:

Same as Client/Applicant

3.3 Specimen Preparation, Conditioning and Timeline

Specimens conditioning and delivery to Laboratory:

Separating element was built by the Laboratory in line with Client instructions. Installation of fire stopping system was performed by the Laboratory in line with Client instructions. The Laboratory was not involved in sampling of the materials. The Laboratory checked materials during construction of the specimen.

Testing date:

21/10/2024

Installation completion date:

13/10/2024

Termination of The Test:

The test was discontinued at 66 minutes.

3.4 Use of the Report

This report shall not be reproduced, except in full.

A regulatory information report was issued in addition to the full test report PF24102. This provides the minimum information required for regulatory compliance.

This report details the methods of construction, test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in AS 1530.4. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than that allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

The test results relate to the specimens of the product in the form in which they were tested. Differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product, which is supplied or used, is fully represented by the specimens, which were tested.

The specimens were supplied by the sponsor and the Laboratory was not involved in any of selection or sampling procedures.

The results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions.

4. Specimen Description

4.1 Supporting Construction

Separating element		
1.1	Item	64mm (nominal) steel stud frame with one layer of 13mm FR Plasterboard fitted to each side of the frame
	Dimensions	Width / Height (W/H): 1200mm x 1200mm

4.2 Specimens

Services		
2.1	Item / Product Name	POLYETHYLENE PAIR COIL INSUALTED REFRIGERATION TUBE - ARDENT ANNEALED COPPER TUBE
	Copper Tube 1	Overall Dimensions (OD): 19.05mm
		Wall Thickness (T): 1.14mm
	Copper Tube 2	Overall Dimensions (OD): 9.52mm
		Wall Thickness (T): 0.81mm
	Insulation	Thickness (T): 16mm
Material	Polyethylene	
2.2	Item / Product Name	ELECTRICAL CABLE 450/750V 2C + E
	Cable Dimensions	Width x Depth (W/D): 14mm x 6.5mm
	Core Dimensions	Overall Diameter (OD): 4mm
		Wire Diameter: 0.85mm
	Earth Dimensions	Overall Diameter (OD): 3.2mm
		Wire Diameter: 0.64mm
2.3	Item / Product Name	MULTICORE ALUMINIUM 4 CORE + EARTH CABLE
	Cable	Diameter (OD): 26.4mm (nominal)
	Conductor	Diameter (OD): 6.9mm (nominal)

2.4	Item / Product Name	MULTICORE ALUMINIUM 4 CORE + EARTH CABLE
	Cable	Diameter (OD): 30.5mm (nominal)
	Conductor	Diameter (OD): 7.4mm (nominal)
		Conductor fine wire EC1350 aluminium, Class 5, to IEC 60228 and AS/NZS 1125
2.5	Item / Product Name	X-90 ELECTRIC CABLE 0.6/1kV 4CX185 SQMM ALUMINIUM CABLE
	Cable	Diameter (OD): 50.8mm
		Extruded Polyvinyl Chloride Compound
	Conductor	Aluminium 1350, compacted Stranded, Sector-shaped, AS / NZS 1125
2.6	Item / Product Name	DN16 PE/AL/PEX NATURAL GAS-LPG
	Dimensions	Diameter (OD): 16mm
		Diameter (ID): 11mm
		Thickness (T): 2.5mm
2.7	Item / Product Name	M12 steel threaded rod
	Dimensions	Diameter (OD): 12.07mm

Sealants

3.1	Item / Product Name	AGNI-Seal
	Dimensions	600mL Sausage
	Installation	Used to seal around edge of separating element and 30mm cone around services (specimens 7-9 & 11). Used to seal around specimen 10.
3.2	Item / Product Name	AGNI-Black
	Dimensions	300mL Cartridge
	Installation	Used to seal between AGNI-Wrap and services

Intumescent

3.1	Item / Product Name	AGNI-Wrap 50
	Dimensions	50mm wide
	Installation	Specimens 1-6


5. Test Results

6.1 Observations during the test

Time min	Test face	SP#	OBSERVATIONS/REMARKS
47	U	8, 9	Sealant beginning to expand
58	U	9	Cable insulation is starting to melt
63	U	ALL	Discolouration of separating element
65			TEST DISCONTINUED

NOTE: E - Exposed Face (inside furnace)
U - Unexposed Face (outside furnace)
SE - Separating element

6.2 Specimen 1




Service penetration details	
Service	2 x PE PAIR COILS + 2 x TPS CABLES
Installation	Installed passing through the separating element
Aperture Size	85mm
Annular Spacing	Min: 3.5mm, Max: 22mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of the separating element
System description	One revolution of 50mm wide AGNI-Wrap inserted into the aperture leaving 10mm past the separating element. 30mm (nominal) deep AGNI-Black applied in the annular gap between the AGNI-Wrap and the services.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	No failure at 66 minutes

6.3 Specimen 2




Service penetration details	
Service	2 x PE PAIR COILS + 2 x TPS CABLES
Installation	Installed on exposed side only
Aperture Size	85mm
Annular Spacing	Min: 3.5mm, Max: 18.5mm

Local Fire-stopping system	
Application	Asymmetrical – applied to the exposed face of the separating element
System description	One revolution of 50mm wide AGNI-Wrap inserted into the aperture leaving 10mm past the separating element. 30mm (nominal) deep AGNI-Black applied in the annular gap between the AGNI-Wrap and the services.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	No failure at 66 minutes

6.4 Specimen 3




Service penetration details	
Service	2 x PE PAIR COILS + 2 x TPS CABLES
Service Support	Unexposed side: Multistrut at 280mm
Installation	Installed on unexposed side only
Aperture Size	85mm
Annular Spacing	Min: 3.5mm, Max: 19mm

Local Fire-stopping system	
Application	Asymmetrical – applied to the unexposed face of the separating element
System description	One revolution of 50mm wide AGNI-Wrap inserted into the aperture leaving 10mm past the separating element. 30mm (nominal) deep AGNI-Black applied in the annular gap between the AGNI-Wrap and the services.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	No failure at 66 minutes

6.5 Specimen 4




Service penetration details	
Service	1 x PE PAIR COIL + 1 x TPS CABLE
Installation	Installed passing through the separating element
Aperture Size	76mm wide x 57mm high oval
Annular Spacing	Min: 3.5mm, Max: 30mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of the separating element
System description	One revolution of 50mm wide AGNI-Wrap inserted into the aperture leaving 10mm past the separating element. 30mm (nominal) deep AGNI-Black applied in the annular gap between the AGNI-Wrap and the services.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	No failure at 66 minutes

6.6 Specimen 5




Service penetration details	
Service	1 x PE PAIR COIL + 1 x TPS CABLE
Installation	Installed on exposed side only
Aperture Size	76mm wide x 57mm high oval
Annular Spacing	Min: 3.5mm, Max: 19.5mm

Local Fire-stopping system	
Application	Asymmetrical – applied to the exposed face of the separating element
System description	One revolution of 50mm wide AGNI-Wrap inserted into the aperture leaving 10mm past the separating element. 30mm (nominal) deep AGNI-Black applied in the annular gap between the AGNI-Wrap and the services.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	65 minutes

6.7 Specimen 6




Service penetration details	
Service	1 x PE PAIR COIL + 1 x TPS CABLE
Installation	Installed on unexposed side only
Aperture Size	76mm wide x 57mm high oval
Annular Spacing	Min: 3.5mm, Max: 18.5mm

Local Fire-stopping system	
Application	Asymmetrical – applied to the unexposed face of the separating element
System description	One revolution of 50mm wide AGNI-Wrap inserted into the aperture leaving 10mm past the separating element. 30mm (nominal) deep AGNI-Black applied in the annular gap between the AGNI-Wrap and the services.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	No failure at 66 minutes

6.8 Specimen 7



Service penetration details	
Service	ALUMINIUM 4 CORE + EARTH CABLE
Installation	Installed passing through the separating element
Aperture Size	35mm
Annular Spacing	Min: 1.5mm, Max: 7.1mm


Local Fire-stopping system	
Application	Symmetrical – applied to both faces of the separating element
System description	Annular gap between the service and wall is sealed with AGNI-Seal. A 30mm x 30mm AGNI-Seal sealant cone applied to seal the gap between cable and separating element.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	No failure at 66 minutes

Figure 17 – Specimen 7 thermocouple temperature rise readings

6.9 Specimen 8




Service penetration details	
Service	ALUMINIUM 4 CORE + EARTH CABLE
Installation	Installed passing through the separating element
Aperture Size	40mm
Annular Spacing	Min: 2mm, Max: 7.5mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of the separating element
System description	Annular gap between the service and wall is sealed with AGNI-Seal. A 30mm x 30mm AGNI-Seal sealant cone applied to seal the gap between cable and separating element.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	66 minutes

6.10 Specimen 9




Service penetration details	
Service	ALUMINIUM 4 CORE CABLE
Installation	Installed passing through the separating element
Aperture Size	60mm
Annular Spacing	Min: 1mm, Max: 8.2mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of the separating element
System description	Annular gap between the service and wall is sealed with AGNI-Seal. A 30mm x 30mm AGNI-Seal sealant cone applied to seal the gap between cable and separating element.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	39 minutes

6.11 Specimen 10




Service penetration details	
Service	DN16 PE/AL/PEX
Installation	Installed passing through the separating element
Aperture Size	25mm
Annular Spacing	Min: 3.5mm, Max: 5.5mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of the separating element
System description	AGNI-Wrap was inserted into the aperture finishing 10mm past the separating element. AGNI-Seal was applied, 10mm (nominal) deep into the gap between the pipe and the AGNI-wrap. 5mm (nominal) AGNI-Seal was used to seal between the AGNI-Wrap and the separating element.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	65 minutes

6.12 Specimen 11



Service penetration details	
Service	12mm THREADED ROD
Installation	Installed passing through the separating element
Aperture Size	25mm
Annular Spacing	Min: 5.4mm, Max: 6.5mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of the separating element
System description	Annular gap between the service and wall is sealed with AGNI-Seal. A 20mm x 20mm AGNI-Seal sealant cone applied to seal the gap between cable and separating element.

Test results

Structural adequacy	Not applicable
Integrity	No failure at 66 minutes
Insulation	No failure at 66 minutes

6. Photos

7.1 Photos before the test




Figure 1 – Unexposed face prior to test commencement



Figure 2 – Exposed face prior to test commencement