

Regulatory Information Report

RIRF24082

**Fire resistance test for penetrations through a
vertical separating element**

Client: Agnitek Pty Ltd

Test method: AS1530.4-2014

Report Date: 27/09/2024

Test number: PF24082




Table of Contents

1.1	Document revision schedule	3
1.2	Signatories	3
2.	Report Summary.....	4
3.	General Information	5
3.1	Testing Scope	5
3.2	Contact Details.....	5
3.3	Specimen Preparation, Conditioning and Timeline	6
3.4	Use of the Report.....	6
4.	Specimen Description.....	7
4.1	Supporting Construction.....	7
4.2	Specimens	8
5.	Test Results.....	11
5.1	Observations during the test	11
5.2	Specimen 2	12
5.3	Specimen 3	13
5.4	Specimen 4	14
5.5	Specimen 5	16
5.6	Specimen 6	18
6.	Photos	19
6.1	Photos before the test	19

1.1 Document revision schedule

Revision #	Date	Description
1	27/09/2024	Issued to Client

1.2 Signatories

Report	Name	Signature	Date
Prepared by:	Alexey Kokorin		27/09/2024
Authorised by:	Andrew Bain (Authorized signatory)		27/09/2024



All tests reported herein have been performed in accordance with the laboratory's scope of accreditation



2. Report Summary

Service penetration was tested passing through one layer of 13mm FR Plasterboard on each side of a 92mm (nominal) steel frame.

Specimen #	Service	Actual Integrity (min)	Actual Insulation (min)	FRL
2	DN32 Pex/Al/Pex Pipe	63NF	63NF	-/60/60
3	Kelox Plus Insulated Pipe	63NF	58	-/60/45
4	D2 Cable Tray	63NF	63NF	-/60/60
5	D1 Cable Tray	63NF	61	-/60/60
6	21mm OD X-90 electric cable	63NF	61	-/60/60

NF – No failure during the test

3. General Information

3.1 Testing Scope

Applicable Standards:

AS 1530.4-2014 Section 10: Service penetrations and control joints

AS 4072.1-2005 (r. 2016) Components for the protection of openings in fire-resistant separating elements. Part 1: Service penetrations and control joints

Departures from Testing Method:

No departures from the testing method

Test conditions:

Conditions complied with the Standard

3.2 Contact Details

Accredited Testing Laboratory

Fire TS Lab - Passive Fire Inspection and Test Services Ltd

Accreditation Number - 1335

1/113 Pavilion Drive, Mangere, Auckland, 2022

New Zealand

Contact e-mail: tests@firelab.co.nz

Client/Applicant:

Agnitek Pty Ltd

8 Clare St, Bayswater, VIC, 3153

Australia

Contact e-mail: info@agnitek.com.au

Manufacturer:

Same as Client/Applicant

3.3 Specimen Preparation, Conditioning and Timeline

Separating element was built by the Laboratory in line with Client instructions. Installation of fire stopping system was performed by the Laboratory in line with Client instructions. The Laboratory was not involved in sampling of the materials. The Laboratory checked materials during construction of the specimen. All services were capped on the fire side.

Testing date:

27/08/2024

Installation completion date:

15/08/2024

Termination of The Test:

The test was discontinued at 63 minutes.

3.4 Use of the Report

This report shall not be reproduced, except in full.

A regulatory information report was issued in addition to the full test report PF24082. This provides the minimum information required for regulatory compliance.

This report details the methods of construction, test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in AS 1530.4. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than that allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

The test results relate to the specimens of the product in the form in which they were tested. Differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product, which is supplied or used, is fully represented by the specimens, which were tested.

The specimens were supplied by the sponsor and the Laboratory was not involved in any of selection or sampling procedures.

The results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions.

4. Specimen Description

4.1 Supporting Construction

Separating element		
1.1	Item	92mm (nominal) steel stud frame with one layer of 13mm FR Plasterboard fitted to each side of the frame
	Dimensions	Width / Height (W/H): 1200mm x 1200mm

Materials		
1.3	Item / Product Name	Steel Stud
	Dimensions	Width / Height (W/H): 92mm x 1200mm, 0.5BMT
	Installation	Used to construct studs in steel frame and nogs
1.4	Item / Product Name	Steel Track
	Dimensions	Width / Height (W/H): 92mm x 1200mm, 0.5BMT
	Installation	Used to construct top and bottom plates in steel frame
1.5	Item / Product Name	Self-Tapping Screw
	Dimensions	10g x 16mm
	Installation	Used to construct steel stud frame – secure studs, tracks and nogs together
1.6	Item / Product Name	FR Plasterboard
	Dimensions	Width / Height (W/H): 1200mm x 1200mm
		Thickness (T): 13mm
Installation	One layer applied to each face of the frame to create separating element	
1.7	Item / Product Name	Self Tapping Screw
	Dimensions	41mm
	Installation	Used to secure GIB Fyreline to frame
1.8	Item / Product Name	Plaster
	Dimensions	5L Pail
	Installation	Used to cover screw heads on plasterboard

1.10	Item / Product Name	AGNI-Seal
	Dimensions	600mL Sausage
	Installation	2mm – 9mm bead of sealant between the GIB Fyreline and refractory frame on both faces

4.2 Specimens

Services		
2.2	Item / Product Name	32mm PE/AL/PEX
	Dimensions	Diameter (OD): 32.3mm
		Diameter (ID): 25.26mm
		Thickness (T): 3.18mm
2.3	Item / Product Name	KM133 KELOX Plus CEW Insulated Pipe
	Dimensions	Diameter (OD): 50mm
		Diameter (ID): 30mm
		Insulation Thickness (T): 15mm nominal
2.4	Item / Product Name	D2 Cable Tray
	Dimensions	Height (Overall): 117mm
		Width (Overall): 321mm
		Depth (Overall): 1353mm
2.5	Item / Product Name	D1 Cable Tray
	Dimensions	Height (Overall): 59mm
		Width (Overall): 444mm
		Depth (Overall): 1209mm
2.6	Item / Product Name	Electra Cable 2023 X-90 0.6/1 kV CU
	Dimensions	Diameter (OD): 20.5mm
	Cable location	1 cable in cavity 6 8 cables in D1 Cable Tray (D)
2.7	Item / Product Name	GARLAND UTPL350HF 240AWG 50PR LSZH CAT2 Cable
	Dimensions	Diameter (OD): 16.5mm
		Wire (OD): 0.5mm

		Cable: 100 wires, 50 pairs
	Cable location	60 cables in D2 Cable Tray
2.8	Item / Product Name	XLPE single-core 0.6/1 kV CU
	Dimensions	Diameter (OD): 41.4mm
		Thickness (T): 2.4mm (insulation)
Cable location	1 cable in D1 Cable Tray (A)	
2.9	Item / Product Name	APEC 2023 X-90 Electra Cable 0.6/1 kV 3C+E CU
	Dimensions	Diameter (OD): 53.8mm
		Thickness (T): 0.7mm (insulation)
Cable location	1 cable in D1 Cable Tray (B)	
2.10	Item / Product Name	Electra Cable 2018 V-90 Electric Cable 0.6/1 kV 6mm ² x 3C+E CU
	Dimensions	Diameter (OD): 16mm
	Cable location	3 cables in D1 Cable Tray (C)

Sealants

3.1	Item / Product Name	AGNI-Seal
	Dimensions	600mL Sausage
	Installation	Used to seal around specimens / services and to create sealant cones

Fixings

4.2	Item / Product Name	Self Tapping Screw
	Dimensions	41mm
	Installation	Used to secure AGNI-Box to steel frame
4.3	Item / Product Name	Self-Tapping Screw
	Dimensions	10g x 16mm
	Installation	Used to construct AGNI-Box steel frame

Intumescent



5.1	Item	AGNI-Sleeve
	Dimensions	Width (W): 168mm
		Thickness (T): 3mm
Installation	Installed around specimen two and three, passed through separating element	

Other		
6.1	Item	AGNI-Coat
	Size	5L pail
	Installation	Used to seal cut edges of AGNI-Board prior to installation
6.2	Item	AGNI-Board
		Thickness (T): 50mm
	Installation	Installed around cable trays – 2 layers finished flush with separating element on both sides
6.3	Item / Product Name	Rondo Steel Stud
	Dimensions	Width / Height (W/H): 92mm x 1200mm
	Installation	Used to create framing for AGNI-Boxes, used for studs in cavity four and five.


5. Test Results

5.1 Observations during the test

Time min	Test face	SP#	OBSERVATIONS/REMARKS
2	U	4, 5	Smoke from cables
11	U	3	Smoke coming from between SE and service
12	E	2, 3	Pipes fallen away from SE
12	U	2	Smoke coming from between SE and pipe
18	U	4	Discolouration of cables
24	U	2, 3	AGNI-Wrap moving into aperture
24	U	2	Discolouration of pipe
26	U	2	Cotton pad test – PASS
27	U	6	Sealant expanding
42	U	2, 3	AGNI-Wrap expanding
48	U	4, 5	Sealant expanding
49	U	2	Cotton pad test – PASS
63			TEST DISCONTINUED

NOTE: E – Exposed Face (inside furnace)
U – Unexposed Face (outside furnace)
SE – Separating element

5.2 Specimen 2




Service penetration details	
Service	32DN KemPex Gas Pipe PN14 PE/AL/PEX
Aperture Size	46.5mm
Annular Spacing	Min: 5mm, Max: 9mm

Local Fire-stopping system	
Application	Symmetrical – installed passing through separating element
System description	<p>The following procedure was followed:</p> <ol style="list-style-type: none"> 1. AGNI-Sleeve was cut to 138mm wide. 2. One revolution of the 138mm wide AGNI-Sleeve was measured and cut to fit the aperture 3. The AGNI-Sleeve was passed through the separating element finishing 10mm past separating element on both faces 4. A bead of AGNI-Seal (5mm nominal) was applied between separating element and AGNI-Sleeve

Test results

Structural adequacy	Not applicable
Integrity	No failure at 63 minutes
Insulation	No failure at 63 minutes

5.3 Specimen 3




Service penetration details	
Service	KM133 KELOX Plus CEW Insulated Pipe
Aperture Diameter	60.5mm
Annular Spacing	Min: 4.0mm, Max: 6.5mm

Local Fire-stopping system	
Application	Symmetrical – installed passing through separating element
System description	<p>The following procedure was followed:</p> <ol style="list-style-type: none"> 1. AGNI-Sleeve was cut to 138mm wide. 2. One revolution of the 138m wide AGNI-Sleeve was measured and cut to fit the aperture 3. The AGNI-Sleeve was passed through the separating element finishing 10mm past separating element on both faces 4. A bead of AGNI-Seal (5mm nominal) was applied between separating element and AGNI-Sleeve

Test results

Structural adequacy	Not applicable
Integrity	No failure at 63 minutes
Insulation	58 minutes

5.4 Specimen 4



Service penetration details	
Service	D2 Cable configuration
Aperture Diameter	418mm x 208mm
Annular Spacing	Min: 2mm, Max: 8mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of separating element
System description	<p>The following procedure was followed:</p> <ol style="list-style-type: none"> 1. A 92mm steel stud was installed 200mm from the refractory frame (right side of cavity) 2. AGNI-Board was cut to fit in the aperture, around the D2 Cable Configuration (2-5mm gap between the AGNI-Board and the services) 3. All AGNI-Board edges were painted with AGNI-Coat 4. AGNI-Board was inserted into aperture around the D2 Cable Configuration 5. AGNI-Seal was applied between the separating element and the AGNI-Board (10mm nominal) 6. AGNI-Seal was applied to fill the gaps between the AGNI-Board and the D2 Cable Configuration (20mm nominal)


	7. AGNI-Seal was applied to all joins in the AGNI-Board (10mm nominal)
--	--

Test results

Structural adequacy	Not applicable
Integrity	No failure at 63 minutes
Insulation	No failure at 63 minutes



5.5 Specimen 5



Service penetration details	
Service	D1 Cable configuration
Aperture Diameter	600mm x 157mm
Annular Spacing	Min: 1mm, Max: 10mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of separating element
System description	<p>The following procedure was followed:</p> <ol style="list-style-type: none"> 1. A 92mm steel stud was installed 200mm from the refractory frame (left side of the cavity) 2. AGNI-Board was cut to fit in the aperture, around the D1 Cable configuration (2-5mm gap between the AGNI-Board and the services) 3. All AGNI-Board edges were painted with AGNI-Coat 4. AGNI-Board was inserted into aperture around the D1 Cable configuration 5. AGNI-Seal was applied between the separating element and the AGNI-Board (10mm nominal) 6. AGNI-Seal was applied to fill the gaps between the AGNI-Board and the D1 Cable configuration (20mm nominal)


	7. AGNI-Seal was applied to all joins in the AGNI-Board (10mm nominal)
--	--

Test results

Structural adequacy	Not applicable
Integrity	No failure at 63 minutes
Insulation	61 minutes



5.6 Specimen 6



Service penetration details	
Service	21mm OD Electra Cable 2023 X-90 0.6/1 kV 3C+E CU
Aperture Diameter	33.5mm
Annular Spacing	Min: 4mm, Max: 9mm

Local Fire-stopping system	
Application	Symmetrical – applied to both faces of separating element
System description	1. AGNI-Seal was applied around the cable to create a 20mm x 20mm sealant cone, sealing between the cable and the separating element

Test results

Structural adequacy	Not applicable
Integrity	No failure at 63 minutes
Insulation	61 minutes

6. Photos

6.1 Photos before the test



Figure 1 – Unexposed face prior to test commencement



Figure 2 – Exposed face prior to test commencement